

# BOSS® 815 Firestop Insert for Electrical Outlet Boxes

### DESCRIPTION

**BOSS® 815** Firestop Insert is an intumescent pad that is inserted into electrical outlet boxes to provide a firestop rating of 1 or 2 hours in gypsum wallboard assemblies. These single component pads have an adhesive back that adheres to the back inside wall of single or double metal outlet boxes. When exposed to fire, these pads expand to completely fill the outlet box and seal any openings, preventing the transfer of heat and flame into the wall cavity and maintaining the fire resistance rating. **BOSS® 815** Firestop Inserts are an alternative to the more traditional putty pads which are installed on the outside of the electrical outlet box. The product is available in two sizes: 2" X 4" for single outlet boxes and 4" X 4" for double outlet boxes.

### FEATURES

- Cost effective – fast and easy to install
- Peel and stick to inside of metal electrical outlet box
- Safe to use, completely non-toxic
- Two standard sizes available – no trimming required
- Intumescent - expands when exposed to heat and fire
- Meets all accoustical requirements

### HOW TO USE

Remove any dirt and construction debris from inside the electrical outlet box. Peel off the protective paper from the adhesive and place the pad against the inside back wall of the box, firmly pushing in place to ensure a strong adhesion. If the outlet box has a ground screw on the inside back panel, make a slit in the pad to access the screw but do not cut any of the pad material away.

### PACKAGING

**BOSS® 815** Firestop Inserts are available in two sizes: 2" X 4" for single outlet boxes and 4" X 4" for double outlet boxes.



### STORAGE AND SHELF LIFE

**BOSS® 815** Firestop Inserts should be stored in their original container at temperatures between 35°F (2°C) and 120°F (49°C). Keep stock rotated.

### LIMITATIONS

Use only in the tested configurations, or as recommended by Accumetric, LLC.

### CAUTION

DIRECT CONTACT OF UNCURED SEALANT IRRITATES EYES AND MAY IRRITATE SKIN. OVEREXPOSURE TO VAPOR MAY IRRITATE EYES, NOSE AND THROAT. Avoid eye and skin contact. Use with adequate ventilation. Do not handle contact lenses with sealant on hands. IN CASE OF EYE CONTACT, flush eyes with water for 15 minutes. Obtain medical attention. IN CASE OF SKIN CONTACT, remove from skin and flush with water. Do not use solvents to remove from skin. IN CASE OF INGESTION, call physician immediately. Clean spills immediately with scrapers and water. Keep container upright and tightly closed, do not reuse. **KEEP OUT OF REACH OF CHILDREN.**

---

## USERS PLEASE READ

The information and data contained herein is believed to be accurate and reliable; however, it is the user's responsibility to determine suitability of use. Since the supplier cannot know all the uses, or the conditions of use to which these products may be exposed, no warranties concerning the fitness or suitability for a particular use or purpose are made.

It is the user's responsibility to thoroughly test any proposed use of our products and independently conclude satisfactory performance in the application.

Likewise, if the application, product specifications or manner in which our products are used requires government approval or clearance, it is the sole responsibility of the user to obtain sure authorization.

The supplier warrants only that its products will meet its specifications. There is no warranty of merchantability or fitness for use, nor any other express or implied warranty. The users exclusive remedy and the suppliers sole liability is limited to refund of the purchase price or replacement of any product shown to be otherwise than as warranted. The supplier will not be liable for incidental or consequential damages of any kind.

Suggestions of uses should not be taken as inducements to infringe any patents.

MANUFACTURED BY

---

**BOSS® PRODUCTS**

**Accumetric, LLC**  
350 Ring Road  
Elizabethtown,  
Kentucky 42701 USA  
800-928-BOSS(2677)  
TEL (270)769-3385  
FAX (270)765-2412

*Outside U.S.*

TEL +1(270)769-3385  
FAX +1(270)765-2412

**Accumetric Asia Pacific, LTD**  
18 Kitpanit Bldg. 5th Floor  
#502 Patpong Road  
Suriyawong, Bangrak  
Bangkok, 10500 Thailand  
TEL (662)634-3060  
FAX (662)634-3066

[www.bossproducts.com](http://www.bossproducts.com)